

## DEKLARACJA ZGODNOŚCI

**Producent:** SATEL Sp. z o.o.  
ul. Budowlanych 66  
80-298 Gdańsk  
tel. (+48 58) 320-94-00  
fax. (+48 58) 320-94-01

**deklaruje na swoją wyłączną odpowiedzialność że**

**produkt:** VERSA 5P – płyta centrali alarmowej

*Opis produktu: Płyta główna centrali alarmowej przeznaczona do instalacji w systemach sygnalizacji włamania i napadu.*

**spełnia wymagania zasadnicze zawarte w Dyrektywach UE:**

**EMC: 2014/30/EU**



**W procedurze oceny zgodności wykorzystane zostały następujące normy zharmonizowane:**

EMC/Odporność            EN 50130-4:2011, EN 61000-6-1:2007

EMC/Emisje                EN 55032:2015, EN 61000-6-3:2007, EN 61000-3-2:2014

Gdańsk, Polska, 19 listopada 2020

A handwritten signature in blue ink, appearing to read 'Mikołaj Liskin', enclosed in a light blue rectangular box.

Mikołaj LISKIN  
Kierownik Działu Badań





**TREZOR TEST s.r.o.**  
**Na Vršku 67, 250 67 Klecany, Czech Republic**

CERTIFICATION BODY NO. 3025  
ACCREDITED BY  
THE CZECH ACCREDITATION INSTITUTE

## CERTIFICATE OF CONFORMITY

Registration number: TT – 205/2020  
for  
**SATEL Sp. z o.o.**  
**Budowlanych 66, 80-298 Gdańsk, Poland**

**PRODUCT**  
(identification): CIE  
Type VERSA 5  
Producer: SATEL Sp. z o.o.  
Budowlanych 66, 80-298 Gdańsk, Poland  
CZ-CPA 27.90.11

**CLASSIFICATION** (of the product): The product is in accordance with the certification scheme 5  
of EN ISO/IEC 17067:2013

and in conformity with requirements of

EN 50131-3:2009, EN 50136-2:2013, EN 50131-10:2014, EN 50136-1:2012,  
EN 50131-6:2017, EN 50131-1:2006/A1:2009/A2:2017

*Security Grade 2,  
Environmental Class II,  
SP2*

The certificate is issued on the basis of certification report no. CE 56/2020  
within the accreditation according to the certificate no. 329/2019 of 28<sup>th</sup> June 2019  
issued by the Czech Accreditation Institute.

Chairman of the Certification board  
CO No. 3025  
Ing. Ladislav POLÁK

Deputy chairman of the Certification board  
CO No. 3025  
Ing. Daniela ČÍŽKOVÁ

Date of publication: 18.06.2020  
Certification date: 28.07.2020  
Certification expiration date: 28.07.2023



This certificate can be used and duplicated only unchanged and with all enclosures.